



*alpha*

Alpha Analytical Laboratories, Inc.

email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

30 May 2024

Pine Mountain Lake Association

Attn: Rick Laffranchi

19228 Pine Mtn. Dr.

Groveland, CA 95321

RE: Routine Coliform

Work Order: 24E2318

Enclosed are the results of analyses for samples received by the laboratory on 05/14/24 13:45. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Rachel J. Kaua

Project Manager



Alpha Analytical Laboratories, Inc. email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)  
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Pine Mountain Lake Association  
19228 Pine Mtn. Dr.  
Groveland, CA 95321

Project Manager: Rick Laffranchi  
Project: Routine Coliform  
Project Number: [none]

Reported:  
05/30/24 12:54

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | 925-828-6226 | ELAP# 2728  
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | 916-686-5190 | ELAP# 2922  
North Bay: 737 Southpoint Blvd Unit D | Petaluma, CA 94954 | 707-769-3128 | ELAP# 2303  
San Diego: 2722 Loker Avenue West Suite A | Carlsbad, CA 92010 | 760-930-2555 | ELAP# 3055  
Los Angeles: 1230 E. 223rd Street Suite 205 | Carson, CA 90745 | 424-267-5032 | ELAP# 3091

#### ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Marina	24E2318-01	Water	05/14/24 08:20	05/14/24 13:45
Lake Lodge	24E2318-02	Water	05/14/24 08:14	05/14/24 13:45
Dunn Ct	24E2318-03	Water	05/14/24 08:10	05/14/24 13:45



Alpha Analytical Laboratories, Inc. email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)  
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Pine Mountain Lake Association  
19228 Pine Mtn. Dr.  
Groveland, CA 95321

Project Manager: Rick Laffranchi  
Project: Routine Coliform  
Project Number: [none]

Reported:  
05/30/24 12:54

	Result	Units	Reporting Limit	Dilution	Batch	Prepared	Analyzed	ELAP#	Method	Note
Marina (24E2318-01)			Sample Type: Water			Sampled: 05/14/24 08:20				
Microbiological Parameters by APHA Standard Methods										
Total Coliforms	17	MPN/100mL	1.8	1	AE44420	05/14/24 14:40	05/18/24 10:32	2922	SM9221B,C	
E. Coli	7.8	MPN/100mL	1.8	1	AE44420	05/14/24 14:40	05/18/24 10:32	2922	SM9221B,F	
Fecal Coliforms	7.8	MPN/100mL	1.8	1	AE44420	05/14/24 14:40	05/18/24 10:32	2922	SM9221B,E	
Lake Lodge (24E2318-02)			Sample Type: Water			Sampled: 05/14/24 08:14				
Microbiological Parameters by APHA Standard Methods										
Total Coliforms	33	MPN/100mL	1.8	1	AE44420	05/14/24 14:15	05/18/24 10:24	2922	SM9221B,C	
E. Coli	7.8	MPN/100mL	1.8	1	AE44420	05/14/24 14:15	05/18/24 10:24	2922	SM9221B,F	
Fecal Coliforms	7.8	MPN/100mL	1.8	1	AE44420	05/14/24 14:15	05/18/24 10:24	2922	SM9221B,E	
Dunn Ct (24E2318-03)			Sample Type: Water			Sampled: 05/14/24 08:10				
Microbiological Parameters by APHA Standard Methods										
Total Coliforms	6.8	MPN/100mL	1.8	1	AE44420	05/14/24 14:15	05/18/24 10:24	2922	SM9221B,C	
E. Coli	ND	MPN/100mL	1.8	1	AE44420	05/14/24 14:15	05/18/24 10:24	2922	SM9221B,F	
Fecal Coliforms	ND	MPN/100mL	1.8	1	AE44420	05/14/24 14:15	05/18/24 10:24	2922	SM9221B,E	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc. email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)  
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Pine Mountain Lake Association  
19228 Pine Mtn. Dr.  
Groveland, CA 95321

Project Manager: Rick Laffranchi  
Project: Routine Coliform  
Project Number: [none]

Reported:  
05/30/24 12:54

#### Notes and Definitions

ND Analyte NOT DETECTED at or above the reporting limit

dry Sample results reported on a dry weight basis

RPD Relative Percent Difference

\* ELAP does not offer accreditation in this matrix for the requested analyte/method combination.

6/2/2022